



NOTES:
1. ALL METAL PIPING COMPONENTS SHALL BE ASSEMBLED BY WELDING, PAINTED WITH CORROSION PROTECTANT COAT AND RED ENAMEL PAINT COAT.
2. RECOMMENDED INSIDE DIMENSIONS 20.5 FT. (6.25m) WIDE x 20.5 FT. (6.25m) LONG x 9.85 FT. (3.0m) DEEP.

REVISED: MARCH 20, 2001 by MK
REVISED: MARCH 4, 2001 by MK

	HIGHLANDS FIRE DEPT. 1564 Millstream Road Victoria, B.C. V9E 1G6 E. Hall (250) 479-1814 * W. Hall (250) 474-2633 Fax (250) 474-3677	TITLE: FD-2A Water Storage Tank Detail LARGE CISTERN ASSEMBLY
	DATE: 16 July 2000 DRAWN: M. Kristiansen	SCALE: AS SHOWN APPROVED: